

Assessment of Compliance to EN 717-1

Edge floor/table/wall

RISE Research Institutes of Sweden received from **Lintex AB** a sample of a sound absorbing panel; Edge floor/table/wall. An emission test has been performed according to M1 Emission Classification of Building Materials: Protocol for Chemical and Sensory Testing of Building Materials”, ver 15.11.2017, see **test report O100152-1181696-1**, dated **2023-04-21**.

The emission result of formaldehyde ($2 \mu\text{g}/\text{m}^2\text{h}$) can be converted into a concentration according to EN 717-1:2004 (Wood-based panels – Determination of formaldehyde release – Part 1: Formaldehyde emission by the chamber method).

In EN 717-1 the area specific air flow rate is $1 \text{ m}^3/\text{m}^2\text{h}$, which means that the concentration equals the emission rate. After adjustment of measuring at different relative humidity (division by 1.09) and partly sealed edges (multiplication by 1.2) the emission of formaldehyde of the tested product expressed as **concentration according to EN 717-1 is $0.002 \text{ mg}/\text{m}^3$** .

According to EN 13986:2004+A1:2015 (Wood-based panels for use in construction – Characteristics, evaluation of conformity and marking) the criteria for Class E1 is less or equal to $0.124 \text{ mg}/\text{m}^3$ measured according to EN 717-1:2004.

The product **Edge floor/table/wall** is in compliance with the formaldehyde requirement of Class E1.

RISE Research Institutes of Sweden AB
Chemistry and Applied Mechanics- Chemical Product Safety

Thomas Vaessen

RISE Research Institutes of Sweden AB

Postal address
Box 857
SE-501 15 BORÅS
Sweden

Office location
Brinellgatan 4
SE-504 62 BORÅS

Phone / Fax / E-mail
+46 10 516 50 00
+46 33 13 55 02
info@ri.se

This document may not be reproduced other than in full,
except with the prior written approval of RISE.

Verification

Transaction 09222115557491699260

Document

O100152-1181696-1-2 EN717-1 Assessment of compliance

Main document

1 page

Initiated on 2023-04-27 12:01:50 CEST (+0200) by

Thomas Vaessen (TV)

Finalised on 2023-04-27 12:01:50 CEST (+0200)

Signing parties

Thomas Vaessen (TV)

RISE Research Institutes of Sweden AB

Company reg. no. 556464-6874

thomas.vaessen@ri.se

Signed 2023-04-27 12:01:50 CEST (+0200)

This verification was issued by Scrive. Information in italics has been safely verified by Scrive. For more information/evidence about this document see the concealed attachments. Use a PDF-reader such as Adobe Reader that can show concealed attachments to view the attachments. Please observe that if the document is printed, the integrity of such printed copy cannot be verified as per the below and that a basic print-out lacks the contents of the concealed attachments. The digital signature (electronic seal) ensures that the integrity of this document, including the concealed attachments, can be proven mathematically and independently of Scrive. For your convenience Scrive also provides a service that enables you to automatically verify the document's integrity at: <https://scrive.com/verify>

